



TRENCH FOR PVC PIPE (15" DIA. AND LESS)

NOT TO SCALE

NOTES:

- 1) WALL THICKNESS SHALL BE SDR 35.
- 2) PVC PIPES REQUIRE #57 WASHED STONE PIPE EMBEDMENT MATERIALS.
- 3) THIS DETAIL IS VALID FOR PVC SEWER PIPE INSTALLED AT DEPTHS OF UP TO 20 FEET.
- 4) PVC PIPE NOT ALLOWED WITH LESS THAN 3'-0" COVER.
- 5) NO BOULDERS OR STONES WILL BE USED IN INITIAL BACKFILL.
- 6) WHEN TRENCH IS SUBJECT TO INUNDATION, EMBEDMENT MATERIALS MUST EXTEND TO TOP OF PIPE.

STANDARD DETAIL

Metropolitan Sewerage District
of
Buncombe County, North Carolina

TRENCH FOR PVC PIPE

APPROVED: FEBRUARY 25, 2010

2.04-01