



NOTES:

1. ANCHOR BOLTS AND STRAPS SHALL BE GALVANIZED STEEL OR STAINLESS STEEL
2. FOR PIPE 24" AND LARGER USE 1" DIA. BOLTS.
3. HOLES TO BE DRILLED IN STRAP.

STANDARD DETAIL	
Metropolitan Sewerage District of Buncombe County, North Carolina	
PIPE STRAP FOR PIERS	
APPROVED: FEBRUARY 25, 2010	2.31-01