

## NOTES:

- 1. ANCHOR BOLTS AND STRAPS SHALL BE GALVANIZED STEEL OR STAINLESS STEEL.
- 2. FOR PIPE 24" AND LARGER USE 1" DIA. BOLTS.
- 3. HOLES TO BE DRILLED IN STRAP.

## STANDARD DETAIL

Metropolitan Sewerage District

of Buncombe County, North Carolina

PIPE STRAP FOR PIERS

DATE APPROVED: MARCH 2017

2.31 - 01