



Metropolitan Sewerage District

OF BUNCOMBE COUNTY, NORTH CAROLINA

July 24, 2026

Lining Contract No. 10
MSD Project No. 2024035

ADDENDUM NUMBER 3

BID DATE: Thursday, July 30, 2026 at 2:30 PM

TO ALL BIDDERS:

This Addendum Number 3 is being sent to all parties showing interest for the above listed project. Please be advised of following:

Technical Specifications Clarification:

1. Under item 6.13 INSTALLATION of the technical specifications, issued under Addendum 1, it is stated in section (a) General, (d), that "the pump and bypass line shall be of adequate capacity and size to handle peak flow." This peak flow shall be considering a peaking factor of 2.5 to ADF. Previous flows given in addendum 2 for the 27-inch segment to be lined are ADF data.

Please acknowledge receipt of this Addendum on the letter written on manufacturers letter head being submitted with the bid. Failure to do so may constitute grounds for rejection of your bid.

Metropolitan Sewerage District of Buncombe County, NC

Tim Hensley, P.E.
MSD Project Manager



~Protecting Our Natural Resources~